

**TABLE 2-5**

**TOWN-WIDE WASTEWATER FLOW ESTIMATES  
(NOT INCLUDING INFILTRATION AND INFLOW)**

<b>CONDITION</b>	<b>FLOW (MGD)</b>
Existing (2003) Average Annual Flow <sup>(1)</sup>	1.0
Build-out (BO) Average Annual Flow	1.3
Build-out Summer Average Flow	2.1
Build-out Minimum Month Flow	0.65
Build-out Maximum Month Flow	2.5
Build-out Peak Day Flow	2.9
Build-out Peak Hourly Flow	4.5
Note: 1. Calculated flow based on 2002-2003 water data and existing Town-wide land use and units based on 2004 Town assessors data.	

**TABLE 2-6**

**INFILTRATION AND INFLOW ESTIMATE**

<b>CONDITION</b>	<b>FLOW (GPD)</b>
Existing Collection System	20,000
Preliminary Gravity Sewer Layout	350,000
Laterals (All Phases)	160,000
Total	530,000